
GOVERNMENT NOTICE

DEPARTMENT OF WATER AFFAIRS

R. 826

25 October 2013

WATER SERVICES ACT, 1997

REGULATIONS RELATING TO COMPULSORY NATIONAL STANDARDS FOR PROCESS CONTROLLERS AND WATER SERVICES WORKS

CORRECTION NOTICE

Government Notice No. 10040, published in Government Gazette No. 36958 of 23 October 2013 is hereby amended as follows:

On page 19, add the following schedule after paragraph 1.6:

SCHEDULE 4

**MINIMUM CLASS OF PROCESS CONTROLLER REQUIRED PER SHIFT, AND SUPERVISION, OPERATIONS AND MAINTENANCE
SUPPORT SERVICES REQUIREMENTS AT A WATER SERVICES WORKS**

WORKS CLASS	CLASS OF PROCESS CONTROLLER PER SHIFT	CLASS OF PROCESS CONTROLLER FOR SUPERVISION*	OPERATIONS AND MAINTENANCE SUPPORT SERVICES REQUIREMENTS*
E	Class I	Class V*	THESE PERSONNEL MUST BE AVAILABLE AT ALL TIMES BUT MAY BE IN-HOUSE OR OUTSOURCED - electrician - fitter - instrumentation technician
D	Class II	Class V*	
C	Class III	Class V*	
B	Class IV	Class V	
A	Class IV	Class V	

NB. Fluoridation – for any class works, minimum process controller classification should be class IV

NOTES FOR SCHEDULES IV

*does not have to be at the water services works at all times but must be available at all times. If the Water Services Institution or owner of a water services works has no person of this class employed on that water services works, a contractor / consultant with the required qualifications as prescribed in Schedule III in respect of that particular class of persons shall be appointed to visit the water services works weekly.