



environmental affairs

Department:
Environmental Affairs
REPUBLIC OF SOUTH AFRICA

Tel: (012) 310 3263

Reference: MP/ES-H/20140227

Enquiries: Vumile Senene

Fax: (012) 322 5545

Email: vsenene@environment.gov.za

Attention: Dave Lucas
Eskom Sustainability Division
P.O. Box 1091
Johannesburg
2001

Dear Applicant,

REQUIREMENT FOR ADDITIONAL INFORMATION FOR THE APPLICATION FOR POSTPONEMENT OF COMPLIANCE WITH THE 2015 MINIMUM EMISSION STANDARDS FOR HENDRINA POWER STATION

This letter serves to inform you that after a preliminary review of your postponement application, the following was observed:

- Current stack emission limits are not supplied;
- There is no indication of compliance into the future for SO₂ and NO_x;
- Ambient air quality monitoring graphs are not presented in time series plots to clearly indicate the trend in air quality as well as exceedances;
- The report does not contain modelled data with isopleth and the position of residential areas;
- No assessment of emissions impact to human health and the environment was conducted.
- Assessment for environmental impact was only conducted for FGD and not for the facility; and
- A detailed assessment of emissions impact on human health and the environment has not been conducted.

In order to continue to consider your application and to make an informed decision, you are required to provide information that addresses the above-mentioned. Please note that your application will be placed on hold until such time the information is made available.

Yours Sincerely,

Dr. Thuli N. Mdluli
NATIONAL AIR QUALITY OFFICER (NAQO)

DATE: 29/05/2014