



environmental affairs

Department:
Environmental Affairs
REPUBLIC OF SOUTH AFRICA

Tel: (012) 310 3263

Reference: MP/ES- KR/20140227
Enquiries: Vumile Senene
Fax: (012) 322 5545 Email: vsenene@environment.gov.za

Attention: Dave Lucas
Eskom Sustainability Division
P.O. Box 1091
Johannesburg
2001

Dear Applicant,

REQUIREMENT FOR ADDITIONAL INFORMATION WITH REGARDS TO THE POSTPONEMENT APPLICATION FOR COMPLIANCE WITH THE 2015 MINIMUM EMISSION STANDARDS FOR THE KRIEL POWER STATION

This letter serves to inform you that after a preliminary review of your postponement application, the following was observed:

- Current stack emission limits are not supplied;
- There is no indication of planned compliance into the future;
- Ambient air quality monitoring graphs are not presented in time series plots to clearly indicate the ambient air quality trends as well as exceedances;
- The frequency plots do not represent monitoring data accurately hence data gaps, trends or time evolution of pollutants cannot be observed;
- There is limited data supplied to undertake the PM_{2.5} health and environmental impact.

In order to continue to consider your application and to make an informed decision, you are required to provide information that addresses the issues raised herein. Please note that your application will be placed on hold until such time the information is made available.

Yours Sincerely,

Dr. Thuli N. Mdluli
NATIONAL AIR QUALITY OFFICER (NAQO)

DATE: 29/05/2014