



environmental affairs

Department:
Environmental Affairs
REPUBLIC OF SOUTH AFRICA

Private Bag X447, Pretoria, 0001 • Environment House, 473 Steve Biko Road, Pretoria, 0002. Tel: +27 12 399 9000, Fax: +27 86 625 1042

Ref: EC/ES-PR/20140227

Enquiries: Mr V. Senene

Tel: 012 399 9217 Fax: 012 359 3619 Email: VSenene@environment.gov.za

Attention: Dave Lucas
Eskom Sustainability Division
P.O. Box 1091
Johannesburg
2001

Dear Applicant,

RE: APPLICATION FOR POSTPONEMENT OF COMPLIANCE TIME-FRAMES WITH NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT 39 OF 2004 S21 MINIMUM EMISSION STANDARDS FOR ESKOM PORT REX POWER STATION

The above-mentioned application has reference.

Your application has been processed and the National Air Quality Officer has made the decision (with the concurrence of the Atmospheric Emission Licensing Authority), as follows:

S21 Category	Appliance	Postponement Sought	Emission Limits			
			Legislated Limits (mg/Nm ³)			Decision
			Pollutant	2015	2020	
Subcategory 1.2: Liquid Fuel Burning Appliances	6 Units	None	PM	75	50	No decision is required because there was no application in this regard. The requirement to comply with minimum emission standards for existing plant thus remains in place.
		None	SO ₂	3500	500	No decision is required because there was no application in this regard. The requirement to comply with minimum emission standards for existing plant thus remains in place.
		750mg/Nm ³ for 2015-2020	NO _x	1100	250	Our finding is that it is possible for the facility to comply with the minimum emission standards for exist plant as the facility currently



TNM

S21 Category	Appliance	Postponement Sought	Emission Limits		
			Legislated Limits (mg/Nm ³)		Decision
					achieves a compliance of 600mg/Nm ³ . Therefore postponement of compliance with the minimum emission standards for new plant is granted from 01 April 2020 to 31 March 2025 with a limit of 600mg/Nm ³ during this period.

** All minimum emission standards are expressed on a daily average basis, under normal conditions of 273 K, 101.3 KPa, 3% oxygen and dry gas.

This decision has to be reflected in your Atmospheric Emission License to be of force and effect. You are required to liaise with the relevant Atmospheric Emission Licensing Authority in this regard as soon as is reasonably possible so that the required amendments, variations and additions to your Atmospheric Emission License can be effected.

Thank you for the co-operation in matters regarding your application.

Yours sincerely,



Dr Thuli N. Mdluli
Department of Environmental Affairs
Designation: National Air Quality Officer

Date: 13/02/2015