



environmental affairs

Department:
Environmental Affairs
REPUBLIC OF SOUTH AFRICA

Private Bag X447, Pretoria, 0001• Environment House, 473 Steve Biko Road, Pretoria, 0002. Tel: +27 12 399 9000, Fax: +27 86 625 1042

Ref: MP/ES-KR/20140227

Enquiries: Mr V. Senene

Tel: 012 399 9217 Fax: 012 359 3619 Email: VSenene@environment.gov.za

Attention: Dave Lucas
Eskom Sustainability Division
P.O. Box 1091
Johannesburg
2001

Dear Applicant,

RE: APPLICATION FOR POSTPONEMENT OF COMPLIANCE TIME-FRAMES WITH NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT 39 OF 2004 S21 MINIMUM EMISSION STANDARDS FOR – KRIEL POWER STATION

The above-mentioned application has reference.

Your application has been processed and the National Air Quality Officer has made the decision (with the concurrence of the Atmospheric Emission Licensing Authority), as follows:

S21 Category	Appliance	Postponement Sought	Emission Standards			
			Minimum Emission Standards (mg/Nm ³)			Decision
			Pollutant	2015	2020	
Subcategory 1.1: Solid Fuel Burning Appliances	6 Units	350mg/Nm ³ for 2015-2020	PM	100	50	Our finding is that the facility currently operates at 125mg/Nm ³ if proper maintenance is done. Postponement of compliance with minimum emission standards for existing plant is granted from 01 April 2015 to 31 March 2020 with a limit of 125mg/Nm ³ during this period. Nonetheless, the facility's refurbishment schedule has been noted and it is recorded that compliance with the 2020 standards is scheduled to take place in 2025.
		2800mg/Nm ³ for 2020-2025	SO ₂	3500	500	



TNm

S21 Category	Appliance	Postponement Sought	Emission Standards			
			Minimum Emission Standards (mg/Nm ³)		Decision	
					existing plant. Therefore postponement of compliance with the minimum emission standard for new plant is granted from 1 April 2020 to 31 March 2025 with a limit of 2800mg/Nm ³ during this period.	
		1600mg/Nm ³	NOx	1100	750	Postponement of compliance with the minimum emission standards for existing plant is granted from 01 April 2015 to 31 March 2020 with a limit of 1600mg/Nm ³ during this period.

*The station is scheduled to decommission between 2030 and 2034 according to the 50 year life span.


** All minimum emission standards are expressed on a daily average basis, under normal conditions of 273 K, 101.3 KPa, 10% oxygen and dry gas.

This decision has to be reflected in your Atmospheric Emission License to be of force and effect. You are required to liaise with the relevant Atmospheric Emission Licensing Authority in this regard as soon as is reasonably possible so that the required amendments, variations and additions to your Atmospheric Emission License can be effected.

In addition, you are to implement an offset programme to reduce PM pollution in the ambient/receiving environment. A definite offset implementation plan is expected from Eskom by 31 March 2016.

Thank you for the co-operation in matters regarding your application.

Yours sincerely,



Dr Thuli N. Mdluli

Department of Environmental Affairs

Designation: National Air Quality Officer

Date: 13/02/2015