




Annual new-build constraints in the IRP

Inputs into South Africa's Integrated Resource Plan 2016

CSIR Energy Centre

Pretoria, 1 December 2016

The logo for CSIR, consisting of the letters 'CSIR' in a large, bold, white sans-serif font.

our future through science

Dr Tobias Bischof-Niemz

Cell: +27 83 403 1108

Email: TBischofNiemz@csir.co.za



IRP 2016: Annual new-build limits for solar PV and wind are constant in absolute terms but decrease relative to the size of the power system

Relative new-build limit = New-build limit / system peak load


Year	System Peak Load in MW	New-build limit Solar PV in MW/yr	Relative new-build limit Solar PV	New-build limit Wind in MW/yr	Relative new-build limit Wind
2020	44 916	1 000	2.2%	1 600	3.6%
2025	51 015	1 000	2.0%	1 600	3.1%
2030	57 274	1 000	1.7%	1 600	2.8%
2035	64 169	1 000	1.6%	1 600	2.5%
2040	70 777	1 000	1.4%	1 600	2.3%
2045	78 263	1 000	1.3%	1 600	2.0%
2050	85 804	1 000	1.2%	1 600	1.9%

Today: Both leading and follower countries install much more new solar PV capacity per year than what South Africa's limit is in 2030

Annual new solar PV capacity relative to system peak load




Today: Solar PV penetration in leading countries 2.5 times RSA's plan for 2050 – follower countries already today almost at RSA's 2050 level




Handwritten signature

Today: Both leading and follower countries install much more new wind capacity per year than what South Africa's limit is in 2050



Annual new wind capacity relative to system peak load




RSA new-build limits in 2030 and 2050



Today: Wind penetration in leading countries almost twice RSA's plan for 2050 – follower countries already today at 60% of RSA's 2050 level





Handwritten signature

Ha Khensa

Re a leboha

Siyathokoza

Enkosi

Thank you

Re a leboga

Ro livhuha

Siyabonga

Dankie