



## environmental affairs

Department:  
Environmental Affairs  
REPUBLIC OF SOUTH AFRICA

Reference: LP/ES-ME/WDM/20170825

Tel: (012) 399 9800

Enquiries: Derrick Makhubele

Email: [d.makhubele@environment.gov.za](mailto:d.makhubele@environment.gov.za)

Attention: Deidre Herbst  
Eskom Holdings SOC Ltd  
Medupi Power Station  
Private Bag X215  
Lephalale  
0555

Dear Applicant,

### APPLICATION FOR POSTPONEMENT OF TIME-FRAMES RELATING TO THE NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT 39 OF 2004 MINIMUM EMISSION STANDARDS FOR MEDUPI POWER STATION

The above-mentioned application has reference.

Your application has been processed and the National Air Quality Officer has, with the concurrence of the Atmospheric Emission Licensing Authority, made a decision as follows:

S21 Category	Appliance	Postponement Sought	Emission Standards		Decision
			Minimum Emission Standards (mg/Nm <sup>3</sup> )		
Subcategory 1.1: Solid Fuel Combustion Installations	6 Units	2015-2020	Pollutant	2015	2020
			SO <sub>2</sub>	3500	500

Postponement of compliance with the minimum emission standards for existing plant is granted for SO<sub>2</sub>, with a limit of **3500 mg/Nm<sup>3</sup>** over a monthly averaging period from 10 September 2018 to 31 March 2020.  
The requirement to comply with the minimum emission standards for new plant as stated in the 2015 postponement decision with a limit of **3500 mg/Nm<sup>3</sup>** over a monthly averaging period from 1 April 2020 to 31 March 2025 thus remains in place. A compliance of **500 mg/Nm<sup>3</sup>** is applicable from 01 April 2025.



**environmental affairs**

Department:  
Environmental Affairs  
**REPUBLIC OF SOUTH AFRICA**

\* All minimum emission standards are expressed as mg/Nm<sup>3</sup> under normal conditions of 10% oxygen, 273 Kelvin and 101.3 kPa.

This decision will have to be reflected in your Atmospheric Emission License to be of force and effect. You are required to liaise with the relevant Atmospheric Emission Licensing Authority in this regard as soon as is reasonably possible so that the required amendments, variations and additions to your Atmospheric Emission License can be effected.

Thank you for the co-operation in matters regarding your application.

Yours sincerely



Dr Thuli N. Khumalo

Department of Environmental Affairs

Designation: National Air Quality Officer

Date: 10/09/2018