

Interested and Affected Party

Date: 15 October 2018

Enquiries: Bryan McCourt
Email: mccourba@eskom.co.za

Ref: ENV18 – L265

DEA Ref.:LP/ES-MT/WDM/20170825

Dear Participant,

RE: APPLICATION FOR POSTPONEMENT OF TIME-FRAMES RELATING TO THE NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT 39 OF 2004 MINIMUM EMISSION STANDARDS FOR MATIMBA AND MEDUPI POWER STATIONS


We refer to the above mentioned application by Eskom Holdings SOC Limited ("Eskom") to the National Air Quality Office (NAQO), for the postponement of compliance time frames relating to Minimum Emission Standards (MES) for Matimba and Medupi Power Stations.

Eskom has in its application dated 30 August 2018 and supporting submissions requested for a postponement of compliance with MES for 'existing plant' for SO₂ and that a monthly averaging limit of 3500 mg/Nm³ be granted for each station. This is to notify you that the above requested postponement has been granted by the NAQO for Matimba and Medupi in letters dated 10 September 2018, attached herein as Annexures A and B respectively.

In summary the stations will be required to comply with a monthly SO₂ limit of 3500 mg/Nm³ until 31 March 2025 and to a limit of 500 mg/Nm³ from 1 April 2025.

Kindly acknowledge receipt of this notification.

Yours faithfully



Deidre Herbst

ESKOM ENVIRONMENTAL MANAGER: RISK AND SUSTAINABILITY