

20170713

# Annexure K

**Mnguni Betty (BHT)**

---

**From:** Wendy Mlotshwa <Wendy.Mlotshwa@arecongroup.com>  
**Sent:** Thursday, July 13, 2017 1:39 PM  
**To:** Ackerman Pieter; Mnguni Betty (BHT)  
**Cc:** Roshantha Nanoolal; asingh@acwapower.com; Prabashen Govender  
**Subject:** RE: Khanyisa Power Station IWWMP: Erosion Protection Designs

Hi Pieter, as per our telephonic conversation – there will not be a continuous discharge of clean storm water as most of the stormwater will be discharged into evaporation ponds.  
In the event of a heavy storm or if the water is not evaporated – the stormwater will overflow into the nearby wetland system

You indicated that you are happy with the concept of using rock embankment; but you'd like the design of the outlet structure to be in form of a pond or basin.

Please confirm that the information supplied above is accurate.

Kind Regards,

**Wendy Mlotshwa** BSc (Hons.) Environmental Science (Cand.Sci.Nat.)  
Environmentalist, Aurecon  
T +27 12 4272490 M +27 60 5714933  
[Wendy.Mlotshwa@arecongroup.com](mailto:Wendy.Mlotshwa@arecongroup.com)

**DISCLAIMER**

**From:** Wendy Mlotshwa  
**Sent:** Thursday, July 13, 2017 10:43 AM  
**To:** Ackerman Pieter <AckermanP@dws.gov.za>; 'Mnguni Betty (BHT)' <MnguniB@dws.gov.za>  
**Cc:** Roshantha Nanoolal <Roshantha.Nanoolal@arecongroup.com>; 'asingh@acwapower.com' <asingh@acwapower.com>; Prabashen Govender <Pgovender@acwapower.com>  
**Subject:** Khanyisa Power Station IWWMP: Erosion Protection Designs  
**Importance:** High

Good morning Pieter and Betty,

I hope you are well.

Attached please find the erosion protection drawing and supporting document as discussed at the meeting on Tuesday. Could you please advise whether the designs will suffice?

Kind Regards,

**Wendy Mlotshwa** BSc (Hons.) Environmental Science (Cand.Sci.Nat.)  
Environmentalist, Aurecon  
T +27 12 4272490 M +27 60 5714933  
[Wendy.Mlotshwa@arecongroup.com](mailto:Wendy.Mlotshwa@arecongroup.com)  
Aurecon Centre, Lynnwood Bridge Office Park, 4 Daventry St, Lynnwood Manor, Tshwane South Africa 0081  
PO Box 74381 Lynnwood Ridge 0040 South Africa  
[arecongroup.com](http://arecongroup.com)